

I can summarise the following information from the transcript. At 0343 hours the ACE Control contacted the National Grid by telephone, this time is confirmed by the transcript, (not available), of the phone conversation. ACE control told the Grid that Wylfa was going to "come off on reactor 1", the Grid appeared happy to receive this information as they were on the minimum generation capacity of the summer. Then followed a conversation between Wylfa and the Grid over what was the most economic time for Wylfa to come off. Wylfa did not want to breach any agreed run-down parameters which would lead to a cost penalty through coming off early. After some deliberation it was agreed that Wylfa would start to come down from full load at 0350 hours and run down within agreed shutdown parameters, which meant that Turbine Alternators 1 & 2 would be off the Grid by 04.55 hours.