



Nuclear Restoration Services Limited  
Hinton House, Birchwood Park Avenue,  
Risley, Warrington, Cheshire, England,  
WA3 6GR.

[REDACTED]  
ONR Fire Safety Inspector  
Office for Nuclear Regulation  
Building 4  
Redgrave Court  
Merton Road  
Bootle  
L20 7HS

Telephone: [REDACTED]  
Email: [REDACTED]

Our Reference: **2025/25667**  
Unique Number: **NRS90077R**

**ONR ENFORCEMENT NOTICE**  
**Accompanying letter**

Date: 14 July 2025

Dear Sir,

**NUCLEAR RESTORATION SERVICES LIMITED**  
**DUNGENESS A (DNA) POWER STATION**  
**REGULATORY REFORM (FIRE SAFETY) ORDER 2005**

The Office for Nuclear Regulation is the enforcing authority under Article 25 of the above Legislation.

ONR has issued Nuclear Restoration Services Limited (NRS) with an Article 30 Enforcement Notice and associated Level 2 Regulatory Issue in regards to compliance with the Regulatory Reform (Fire Safety) Order 2005.

**Background:**

ONR were made aware of fire safety deficiencies in relation to the Fill House at DNA and following enquiries consider that these represent shortfalls in regards to compliance with the Regulatory Reform (Fire Safety) Order 2005. The fire safety deficiencies in this area were also subject to an Apparent Cause Investigation report (ACI), conducted by DNA, which identified shortfalls both at DNA and in NRS corporate arrangements.

**Regulatory Requirements:**

I am writing to NRS as the 'responsible person' under Article 3 of the Regulatory Reform (Fire Safety) Order 2005.



The provisions of the Regulatory Reform (Fire Safety) Order 2005 which have not been complied with are:-

Article 9.—(1) - Risk assessment. The responsible person must make a suitable and sufficient assessment of the risks to which relevant persons are exposed for the purpose of identifying the general fire precautions he needs to take to comply with the requirements and prohibitions imposed on him by or under this Order.

Article 11.—(1) – Fire safety arrangements. The responsible person must make and give effect to such arrangements as are appropriate, having regard to the size of his undertaking and the nature of its activities, for the effective planning, organisation, control, monitoring and review of the preventive and protective measures.

Article 13 — (1) - Firefighting and fire detection. Where necessary (whether due to the features of the premises, the activity carried on there, any hazard present or any other relevant circumstances) in order to safeguard the safety of relevant persons, the responsible person must ensure that the premises are, to the extent that it is appropriate, equipped with appropriate firefighting equipment and with fire detectors and alarms.

To determine the appropriate enforcement decision, I have applied the ONR Enforcement Management Model which, for these circumstances, has resulted in an Article 30 Enforcement Notice.

Compliance with the attached Enforcement Notice is a legal requirement to which you have a right of appeal to a Magistrates' Court. Your attention is drawn to the notes that accompany this Notice.

**Remedial Action required:**

The matters and steps described below and specified on the Schedule attached to the notice need to be carried out to remedy this failure.

I require that:

Nuclear Restoration Services complete the actions attached to the Enforcement Notice to deliver the required improvements under Articles 9, 11 and 13 of the Regulatory Reform (Fire Safety) Order 2005.

Please write to me by 30 September 2025 to tell me how the above actions have been addressed.

I will arrange to receive regular updates on progress with the actions above which will be monitored through a Level 2 Regulatory Issue (Reference RI-12606) which has been placed on the ONR issues database.

You should note that if ONR is not satisfied that appropriate action has taken place, then in accordance with ONR Enforcement Policy Statement, we will consider further enforcement action.



**Information for employees**

Section 28(8) of the Health and Safety at Work etc. Act 1974 requires me to give information to your employees about matters affecting their health, safety and/or welfare. I have, therefore, sent a copy of this letter to the employees for their information.

Yours faithfully,

[REDACTED]  
**ONR Fire Safety Inspector**

**Distribution**

ONR

[REDACTED]  
[REDACTED]  
[REDACTED]

NRS

[REDACTED]  
[REDACTED]  
[REDACTED]  
[REDACTED]  
[REDACTED]