Westinghouse UK AP1000® GENERIC DESIGN ASSESSMENT Resolution Plan for GI-AP1000-HF1 Completeness of the Human Factors Safety Case

MAIN ASSESSMENT AREA	RELATED ASSESSMENT AREA(S)	RESOLUTION PLAN REVISION	GDA ISSUE REVISION	
Human Factors	-	1	0	

GDA ISSUE:	Completeness of the Human Factors Safety Case, specifically in the areas of human error mechanisms, operator misdiagnosis potential and violation potential.
ACTION: GI-AP1000-HF- 01.A1	Westinghouse submitted a significant volume of important HF analysis towards the end of GDA Step 4 relating to human error mechanisms, operator misdiagnosis and violation potential. ONR undertook a very high review of the submission to gain confidence in the approach, but was unable to undertake a detailed and thorough assessment within the Step 4 timescales. This GDA Issue Action requires Westinghouse to support ONR's full assessment of this submission; specifically Westinghouse should: • Provide adequate responses to questions raised from ONR assessment of documents submitted during Step 4. With agreement from the Regulator this action may be completed by alternative means.

RELEVANT REFERENCE DO	CUME	NTATI	ON RELA	TED TO GDA	ISSUE	
Technical Queries			TQ and	Subject	Response Date	Status
	-			the Human Factors Safety Case	4 Feb 2011	Closed - Full Response
		TQ-AP1000-1	f Revision A of the PCSF 177 - HF issue tracking	and resolution (TQ-AP1000-908	16 Dec 2010	Sent Closed - Full Response
		follow on) TQ-AP1000-1	163-Fire arrangements		26 Nov 2010	Closed - Full Response Sent
		TQ-AP1000-1144-Queries relating to Supplemental Submission 'Potential Improvements as proposed in the ALARP analysis' TQ-AP1000-1143-Overarching ALARP approach TQ-AP1000-1133 - Aligning CVS to aux spray TQ-AP1000-1131 - Computer formats TQ-AP1000-1129 - Temperatures and atmospheric conditions		13 Dec 2010	Closed - Full Response Sent	
				10 Dec 2010	Closed - Full Response Sent	
				15 Nov 2010	Closed - Full Response Sent	
				26 Nov 2010	Closed - Full Response Sent	
				17 Nov 2010	Closed - Full Response Sent	
		TQ-AP1000-1128 - Local-to-Plant Controls		30 Nov 2010	Closed - Full Response Sent	
		TQ-AP1000-1126 - Maintenance task target times		15 Nov 2010	Closed - Full Response Sent	
		TQ-AP1000-1	CQ-AP1000-1112 - Maintenance - Adjunct/Peripheral Systems		23 Nov 2010	Closed - Full Response Sent
		TQ-AP1000-1111 - Maintainability Guidelines			24 Nov 2010	Closed - Full Response Sent
		TQ-AP1000-1	110 - Maintenance cons	sideration in OEF reviews	24 Nov 2010	Closed - Full Response Sent
		TQ-AP1000-1	096 - FLISM Operator A	ction time	28 Oct 2010	Closed - Full Response Sent Closed - Full Response
		TQ-AP1000-1	095 - Changes to EOP E	-3, APP-GW-GJP-204	15 Oct 2010	Sent
			084 - SQUIB Valve HF Is		17 Nov 2010	Closed - Full Response Sent Closed - Full Response
		TQ-AP1000-1083 - Normal and passive RHR issues TQ-AP1000-1082 - Relative humidity information			28 Oct 2010	Sent Closed - Full Response
					2 Nov 2010	Sent Closed - Full Response
		TQ-AP1000-1081 - Deterioration of lighting levels		5 Nov 2010 15 Oct 2010	Sent Closed - Full Response	
		TQ-AP1000-1080 - Operator action times TQ-AP1000-1004 - Anthropometric Data		30 Oct 2010	Sent Closed - Full Response	
		TQ-AP1000-908 - HF Issues List TQ-EPR-901 - Dissemination of Human Factors guidance to suppliers		15 Oct 2010	Closed - Full Response	
				8 Oct 2010	Closed - Full Response	
		TQ-AP1000-900 - Human Factors organisation				Closed - Full Response Sent
		TQ-AP1000-6	60 - Tailoring AP1000 to	o UK national requirements	22 Nov 2010	Closed - Full Response Sent
Regulatory Observations	RO-AF RO-AF	1000	-96			
Other Documentation	Document Date Title		Subject Matter			
	UN REG WEC 000464		30 December 2010	Westinghouse AP1000 Human Factors Document Submission	UKP-GW-GL-075, Revision 0; "United Kingdom AP1000 Supplemental Information for the UK AP1000 Human Factors Safety Case – Additional UK Fault Schedule Faults"	
	UN REG WEC 000453		17 December 2010	Westinghouse Response to Regulatory Observations RO- AP1000 -90, RO- AP1000 -96, and RO- AP1000 -97	UKP-GW-GL-076, revision 0; "United Kingdom AP1000 Supplemental Information for the UK AP1000 Human Factors Safety Case – Operator Error Mechanisms"	
	UN REC		16 December 2010	Submittal of UKP-GW-GL- 144 Revision 1	"AP1000 UK Categorization Classification	

UN REG WEC 000475	16 December 2010	Revised C&I GDA Scope	High-level scope statement for the GDA for the AP1000 C&I application and platforms
UN REG WEC 000438	2 December 2010	Westinghouse AP1000 Human Factors Document Submission	UKP-GW-GL-074, Rev 0; "Supplemental Information for the UK AP1000 Human Factors Safety Case - AP1000 Maintainability"
UN REG WEC 000418,	4 November 2010	Westinghouse AP1000 Human Factors Document Submission	UKP-GW-GL-069, Revision 0; "United Kingdom AP1000 Supplemental Information for the UK AP1000 Human Factors Safety Case as Reflecting the UK AP1000 PRA Update"
UN REG WEC 000377	1 October 2010	Westinghouse AP1000 Human Factors Document Submission: "AP1000 Local Panels and Maintainability HFE Assessment"	APP-OCS-JCR-001, Rev A; AP1000 Local Panels and Maintainability HFE Assessment"
UN REG WEC 000150	26 February 2010	Westinghouse AP1000 Human Factors Safety Case Submission	UKP-GW-GL-042, Rev. 1; "AP1000 Human Factors Program and Assessment for the United Kingdom"

Scope of Work:

In acknowledgement of ONR's continuing assessment of the **AP1000**[®] Human Factors Safety Case, the scope of work associated with this Resolution Plan is defined as Westinghouse's facilitation of the ONR review through appropriate and timely responses to Technical Queries, attendance at meetings, and provision of requested supporting documentation.

Description of Work:

Westinghouse shall formally respond to ONR-supplied Technical Queries as documented through the normal GDA processes, actively participate in subject meetings and telephone conferences, and provide relevant supporting technical documentation.

Schedule / Programme Milestones:

The schedule for this Scope of Work is dependent upon the ONR review activities; however, it is expected that the total assessment completion and corresponding Westinghouse support period shall be within 4 calendar months of the ONR review initiation.

Methodology:

Westinghouse responses to ONR Technical Queries and provision of supporting documents

shall be based on existing relevant technical information and in accordance with the existing GDA processes. Further, meetings and conferences shall be held on a Level 4 basis as defined by existing GDA processes.

Justification of Adequacy:

The previously supplied body of supporting information to the **AP1000** Human Factors Safety Case was designed and developed to augment the original Safety Case submission. As such, this information reflected Westinghouse's response to the relevant Regulatory Observations as identified above. The scope of work identified herein provides the same level of support to the ONR assessment as during the Step 4 GDA activities.

Impact Assessment:

As the Safety Case augmentation to be reviewed addresses each of the Regulatory Observations, minimal impact to the existing **AP1000** Human Factors Safety Case is expected.